

Saint-Gobain Construction Products Rus LLC



Thermo-technical calculation

SP 50.13330.2012

“Thermal protection of buildings”

VIRMAK

Initial data**Type of construction:** Sandwich wall**Territory:** Krasnodar Region, Krasnodar

t_{ext} Design external air temperature: (reliability of 0.92, SP 131.13330.2012 t.3.1)	- 16 °C
t_{ht} Design average air temperature of heating season: (with daily average temperature $t \leq 8^{\circ}\text{C}$, SP 131.13330.2012 t.3.1)	2.5 °C
z_{ht} Duration of heating season: (with daily average temperature $t \leq 8^{\circ}\text{C}$, SP 131.13330.2012 t.3.1)	145 days
Humidity area	dry

Intended use of building and room

Building: residential unit

Room: habitable room

Coefficient a: (SP 50.13330.2012, t.3)	0.00035
Coefficient b: (SP 50.13330.2012, t.3)	1.4
a_{int} - Internal film heat-transfer coefficient: (as per SP 50.13330.2012, t.4)	8.7
Rate temperature drop between temperature of internal air and temperature of internal surface of enclosing structure: (as per SP 50.13330.2012, t.5)	4°C
a_{ext} - External film heat-transfer coefficient: (as per SP 50.13330.2012, t.6)	12
t_{int} Temperature of staying: (as per GOST 30494-2011)	20°C
ϕ - Relative humidity: (as per GOST 30494-2011, SP 131.13330.2012, t.3.1)	no more than 60%
Moist room conditions: (SP 50.13330.2012, t.1)	regular
Enclosing structures operation practices: (SP 50.13330.2012, t.2)	A
Coefficient of structure uniformity r: (as per GOST R 54851-2011)	0.8
Dependency ratio of enclosing structure position n: (SP 50.13330.2012, f.5.3)	1

Makeup of structure

No.	Layer	Thickness, mm	Note
1	Cement bonded particleboard	12	$\lambda = 58 \text{ W/(m } ^\circ\text{C)}$
2	Thermal insulating layer ISOVER Sandwich LIFE	110	$\lambda = 0.04 \text{ W/(m } ^\circ\text{C)}$ $\mu = 0.3 \text{ mg/ m}\cdot\text{h}\cdot\text{Pa}$
3	Cement bonded particleboard	12	$\lambda = 58 \text{ W/(m } ^\circ\text{C)}$

Heating season degree-day (HSDD):

(SP. 50.13330.2012 f.5.2)

$$\text{HSDD} = (t_{\text{int}} - t_{\text{ht}}) \times z_{\text{ht}} = (20 - 2.5) \times 145 = 2537.5 \frac{^\circ\text{C} \times \text{days}}{\text{year}}$$

Normalized heat transfer resistance:

(SP 50.13330,2012)

$$R_{0 \text{ norm}} = (a \times \text{HSDD} + b) \times n = (0.00035 \times 2537.5 + 1.4) \times 1 = 2.288 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

Calculation of heat transfer resistance

CBPB, homogeneous layer, $\delta=12 \text{ mm}$, $\lambda=58 \text{ W/(m } ^\circ\text{C)}$

Heat transfer resistance:

$$R_1 = \frac{\delta}{\lambda} = \frac{12 \times 10^{-3}}{58} = 0 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

CBPB, homogeneous layer, $\delta=12 \text{ mm}$, $\lambda=58 \text{ W/(m } ^\circ\text{C)}$

Heat transfer resistance:

$$R_2 = \frac{\delta}{\lambda} = \frac{12 \times 10^{-3}}{58} = 0 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

Calculation of an approximate heat transfer resistance of insulant

$$R_{\text{ins}} = \frac{R_{0 \text{ norm}}}{r} - R_1 - R_2 - \frac{1}{\alpha_{\text{int}}} - \frac{1}{\alpha_{\text{ext}}} =$$

$$\frac{2.288}{0.8} - 0 - 0 - \frac{1}{8.7} - \frac{1}{12} = 2.662 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

Calculation of an approximate thickness of insulant layer from condition:

$$R_{\text{ins}} = \frac{\delta_{\text{ins}}}{\lambda_{\text{ins}}} = 2.662 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

where $\lambda_{\text{ins}} = 0.04 \text{ W/(m } ^\circ\text{C)}$

$$\delta_{\text{ins}} = R_{\text{ins}} \times \lambda_{\text{ins}} = 2.662 \times 0.04 = 106.48 \text{ mm}$$

Due to the multiplicity of materials, the thickness of thermal insulating layer is taken to be equal to $\delta_{\text{thick}} = 110$ mm. Then the reduced total thermal resistance:

$$R_{\text{rd}} = r \times \left(\frac{1}{\alpha_{\text{int}}} + \frac{1}{\alpha_{\text{ext}}} + \frac{\delta_{\text{thick}}}{\lambda_{\text{ins}}} + R_1 + R_2 \right) =$$

$$0.8 \times \left(\frac{1}{8.7} + \frac{1}{12} + \frac{110 \times 10^{-3}}{0.04} + 0 + 0 \right) = 2.359 \frac{\text{m}^2 \times \text{°C}}{\text{W}}$$

The condition $R_{0\text{norm}} \leq R_{\text{rd}}$ is fulfilled: $2.288 \leq 2.359$.

Sanitary requirements

Calculation of temperature drop between temperature of internal air and temperature of internal surface of enclosing structure:

$$\Delta t_{\text{dr}} = \frac{n \times (t_{\text{int}} - t_{\text{ext}})}{R_{\text{thick}} \times \alpha_{\text{int}}} = \frac{1 \times (20 - 16)}{2.359 \times 8.7} = 1.75 \text{°C}$$

The condition $\Delta t_{\text{rated}} \geq \Delta t_{\text{dr}}$ is fulfilled: $4 \geq 1.75$

The temperature of internal surface – T_i , °C of enclosing structure (not including heat-conducting factor) shall be calculated according to the formula:

$$T_i = t_{\text{int}} - \Delta t_{\text{dr}} = 20 - 1.75 = 18.25 \text{°C}$$

The condition $T_i \geq t_{\text{cond}}$ is fulfilled : $18.25 \geq 12$

where t_{cond} stands for condensing point temperature.

$$\gamma(t_{\text{int}}, \phi) = \frac{17.27 \times t_{\text{int}}}{237.7 + t_{\text{int}}} + \log(\phi \times 0.01) = \frac{17.27 \times 20}{237.7 + 20} + \log(60 \times 0.01) = 0.83$$

$$t_{\text{cond}} = \frac{237.7 \times \gamma(t_{\text{int}}, \phi)}{17.27 - \gamma(t_{\text{int}}, \phi)} = 12 \text{°C}$$


Heating pattern in structural section

The temperature t_x , °C of enclosing structure in plane corresponding to the layer x boundary, shall be calculated according to the formula:

$$t_x(x) = t_{\text{int}} - \frac{(t_{\text{int}} - t_{\text{ext}}) \times R_x(x)}{R_{\text{rd}}}$$

$$R_x(x) = \frac{1}{\alpha_{int}} + \sum_{i=1}^x R_i$$

where x stands for the number of layer, x=0 stands for the internal space, R_i stands for heat transfer resistance of layer with number I, in the direction from internal space.



Point 1: $t_{int} = 20^{\circ}\text{C}$ – temperature inside the room

Point 2: $t_x(0) = 18.66^{\circ}\text{C}$ – temperature at the internal boundary of layer No.1 – “CBPB”

$$R_x(0) = \frac{1}{\alpha_{int}} + \sum_{i=1}^0 R_i = \frac{1}{8.7} = 0.11 \frac{\text{m}^2 \times ^{\circ}\text{C}}{\text{W}}$$

$$t_x(0) = t_{int} - \frac{(t_{int} - t_{ext}) \times R_x(0) \times r}{R_{rd}} = 20 - \frac{(20 + 16) \times 0.11 \times 0.8}{2.359} = 18.66^{\circ}\text{C}$$

Point 3: $t_x(1) = 18.66^{\circ}\text{C}$ – temperature at boundary of layer No.1 “CBPB” and layer No.2 *ISOVER Sandwich Life*

$$R_x(1) = \frac{1}{\alpha_{int}} + \sum_{i=1}^1 R_i = \frac{1}{8.7} + 0 = 0.11 \frac{\text{m}^2 \times ^{\circ}\text{C}}{\text{W}}$$

$$t_x(1) = t_{int} - \frac{(t_{int} - t_{ext}) \times R_x(1) \times r}{R_{rd}} = 20 - \frac{(20 + 16) \times 0.11 \times 0.8}{2.359} = 18.66^\circ\text{C}$$

Point 4: $t_x(2) = -14.92^\circ\text{C}$ – temperature at boundary of layer No.2 *ISOVER Sandwich Life* and layer No.3 “CBPB”

$$R_x(2) = \frac{1}{\alpha_{int}} + \sum_{i=1}^2 R_i = \frac{1}{8.7} + 0 + 2.75 = 2.86 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

$$t_x(2) = t_{int} - \frac{(t_{int} - t_{ext}) \times R_x(2) \times r}{R_{rd}} = 20 - \frac{(20 + 16) \times 2.86 \times 0.8}{2.359} = -14.92^\circ\text{C}$$

Point 5: $t_x(3) = -14.92^\circ\text{C}$ – temperature at the outside boundary of layer No. 3 - “CBPB”

$$R_x(3) = \frac{1}{\alpha_{int}} + \sum_{i=1}^3 R_i = \frac{1}{8.7} = 2.86 \frac{\text{m}^2 \times ^\circ\text{C}}{\text{W}}$$

$$t_x(3) = t_{int} - \frac{(t_{int} - t_{ext}) \times R_x(3) \times r}{R_{rd}} = 20 - \frac{(20 + 16) \times 2.86 \times 0.8}{2.359} = -14.92^\circ\text{C}$$

Point 6: $t_{ext} = -16^\circ\text{C}$ - outside temperature

Determination of the plane of a maximum moistening (condensation)

This is a calculation procedure based on the use of method of dimensionless characteristics.

The value of f_i ($t_{\text{max.m.}}$), an indicative of the temperature in the plane of maximum moistening, shall be calculated for each layer of multilayer structure.

No. of layer	Layer of structure	$R_{ni} = \delta i / \mu i$	$\mu i / \lambda i$
Internal surface of enclosing structure		$R_{int, vp} = 0.0266$	0
1	CBPB	0	0
2	ISOVER Sandwich Life	$0.11 / 0.3 = 0.367$	$0.3 / 0.04 = 7.5$
3	CBPB	0	0
Outside surface of enclosing structure		$R_{ext, vp} = 0.0133$	0

$R_{int, vp}$ and $R_{ext, vp}$ – resistance to moisture exchange respectively of internal and outside surfaces of enclosing structure, ($\text{m}^2 \cdot \text{h} \cdot \text{Pa} / \text{mg}$).

Note:

- Resistance to vapour permeability of close air spaces in enclosing structures shall be taken as equal to zero regardless the position and thickness of these spaces.
- Layers of structure, located between an air space, ventilated with outside air, and outside surface of enclosing structure shall not be taken into calculation.

$$f_i(t_{\max, \text{moist.}}) = \frac{5330 \times R_{0, \text{dr}} \times (t_i - t_{\text{ext. bel. zero}}) \times \mu_i}{R_{0, \text{con}} \times (e_{\text{int}} - e_{\text{ext. bel. zero}}) \times \lambda_i}$$

$$R_{0, \text{dr}} = \sum_i \frac{\delta_i}{\mu_i} = 0.0266 + 0 + 0.367 + 0 + 0.0133 = 0.4069 \frac{\text{m}^2 \times \text{h} \times \text{Pa}}{\text{mg}}$$

E_{sat} - partial pressure of saturated steam, Pa, at the air temperature from -40 to +45 °C is determined according to the formula:

$$E(t) = 1.84 \times 10^{11} \times \exp\left(\frac{-5330}{273 + t}\right)$$

For the temperature $t_{\text{sat}} = 20$ °C:

$$E_{\text{sat}} = E(20) = 1.84 \times 10^{11} \times \exp\left(\frac{-5330}{273 + 20}\right) = 2314.79 \text{ Pa}$$

e_{int} - partial pressure of saturated steam of internal air, Pa, at the designed temperature and relative humidity in room is determined according to the formula:

$$e_{\text{int}} = \left(\frac{\phi_{\text{int}}}{100}\right) \times E_{\text{sat}} = \left(\frac{60}{100}\right) \times 2314.79 = 1388.87 \text{ Pa}$$

$e_{\text{ext. bel. zero}}$ - partial pressure of saturated steam of external air for the period of months with below zero monthly average temperature is determined according to SP 131.13330:

$$e_{\text{ext. bel. zero}} = 100 \times 4.9 = 490 \text{ Pa}$$

$t_{\text{ext. bel. zero}}$ – average temperature of external air for the period of months with below zero monthly average temperature is determined according to SP 131.13330:

$$t_{\text{ext. bel. zero}} = -0.2 = -0.2 \text{ °C}$$

μ_i/λ_i – the ratio of heat-transfer coefficients, W/(m² x °C), and steam permeability, mg/(m x h x Pa), of material of corresponding layer, or 0 if the coefficients are not set.

$$f_i(t_{\max, \text{moist.}}) = \frac{5330 \times R_{0, \text{rd}} \times (t_i - t_{\text{ext. bel. zero}}) \times \mu_i}{R_{0, \text{con}} \times (e_{\text{int}} - e_{\text{ext. bel. zero}}) \times \lambda_i} = \frac{5330 \times 0.4069 \times (20 + 0.2) \times \mu_i}{2.949 \times (1388.87 - 490) \times \lambda_i} = 16.53 \times \left(\frac{\mu_i}{\lambda_i}\right)$$

$$f_1(t_{\text{max.moist}}) = 16.53 \times 0 = 0$$

$$f_2(t_{\text{max.moist}}) = 16.53 \times 7.5 = 123.98$$

$$f_3(t_{\text{max.moist}}) = 16.53 \times 0 = 0$$

According to SP 50.13330 table 11, when $f_i(t_{\text{max.moist}})$ is not negative, than $t_{\text{max.moist}}$ can be calculated according to formula:

$$t_{\text{max.moist}} = \frac{\left(a \times b + c \times f \left(t_{\text{max.moist}} \right)^d \right)}{\left(b + f \left(t_{\text{max.moist}} \right)^d \right)}$$

$$a = 96.6680675349$$

$$b = 4.89349504771$$

$$c = -66.4983819958$$

$$d = 0.406903783624$$

$$t_{\text{max.moist.1}} = \frac{(a \times b + c \times 0^d)}{(b + 0^d)} = 96.668$$

$$t_{\text{max.moist.2}} = \frac{(a \times b + c \times 123.98^d)}{(b + 123.98^d)} = 0.027$$

$$t_{\text{max.moist.3}} = \frac{(a \times b + c \times 0^d)}{(b + 0^d)} = 96.668$$

Calculation of temperature at boundaries of layers

$$t_{\text{t.layer } k} = t_i - \left(\frac{t_i - t_{\text{ext.bel.zero}}}{R_{0 \text{ con}}} \right) \times \left(\frac{1}{\alpha_{\text{int}}} + \sum_{i=1}^k R_i \right)$$

where R_i – heat transfer resistance of the layer I (or 0 if this layer is not included in thermo-technical calculation), k – number of layer for which the temperature is calculated.

$$t_{\text{t.layer } 0} = 20 - \left(\frac{20 + 0.2}{2.949} \right) \times \left(\frac{1}{8.7} \right) = 19.21^\circ\text{C}$$

$$T_{t.layer 1} = 20 - \left(\frac{20 + 0.2}{2.949} \right) \times \left(\frac{1}{8.7} + 0 \right) = 19.21^{\circ}\text{C}$$

$$T_{t.layer 2} = 20 - \left(\frac{20 + 0.2}{2.949} \right) \times \left(\frac{1}{8.7} + 0 + 2.75 \right) = 0.38^{\circ}\text{C}$$

$$T_{t.layer 3} = 20 - \left(\frac{20 + 0.2}{2.949} \right) \times \left(\frac{1}{8.7} + 0 + 2.75 + 0 \right) = 0.38^{\circ}\text{C}$$

Summary table $t_{max.moist.}$ and $T_{t.layer k}$

This is the table that includes the value of $t_{max.moist.}$ for each layer and temperatures at boundaries of layers (at average temperature of external air in a period of below zero monthly average temperatures):

No. of layer	Layer of the structure	$T_{t.layer k}, ^{\circ}\text{C}$	$t_{max.moist.}, ^{\circ}\text{C}$
0	CBPB	19.21	96.668
1		19.21	
1	ISOVER Sandwich Life	19.21	0.027
2		0.38	
2	CBPB	0.38	96.668
3		0.38	

Determination of the maximum moistening plane

As you can see in the table, there is not a single layer with a temperature of $t_{max.moist.}$ within the limits of $\tau_{t.layer}$. Also, there are no pairs of adjacent layers where the condition $t_{max.moist.} > \max(\tau_{t.layer})$ for the colder layer and the condition $t_{max.moist.} > \max(\tau_{t.layer})$ for the warmer layer are satisfied.

In this case, the plane of maximum moistening is taken on the external surface of the structure. **Protection from excessive moistening is not required.**

The structural components does not require additional measures to protect against excessive moistening.

Conclusion

The structure is designed to meet the requirements of SP 50.13330.2012 "Thermal protection of buildings" and SP 131.13330.2012 "Construction Climatology".

The thickness of the thermal insulation layer of ISOVER Sandwich Life is 110 mm. According to the calculation:

- The structural components meet the requirements for thermal protection.
- The structural components meet the sanitary and hygienic requirements.
- The structural components does not require additional measures to protect against excessive moistening.

Where to buy

Saturn-Krasnodar JSC Address: Krasnodar, Krasnodar, Uralskaya St., bld. 128	Phone: +7 (861) 212-66-00 Website: http://krd.saturn.net
GK Sibirskiy Biznes Address: Krasnodar, Krasnodar, Ippodromnaya Str. 1/1	Phone: +7 (861) 210-04-10 Website: http://www.sbiznes.ru
GK Sibirskiy Biznes Address: Krasnodar, Krasnodar, Ippodromnaya Str. 1/1	Phone: +7 (861) 210-08-87 Website: http://www.sbiznes.ru
ALEA LLC Address: Krasnodar, Krasnodar, Novorossiyskaya Str. bld. 236	Phone: 8-800-200-26-59 Website: https://krd.aleacompany.ru/
GrandLine-Center LLC Address: Krasnodar, Krasnodar, Dzerzhinsky Str, bld. 112	Phone: +7 (861) 258-33-87 Website: http://yugmontag.ru
METAL PROFILE Company LLC Address: Krasnodar, Krasnodar, Garazhnaya Str., bld. 91	Phone: +7 (861) 253-53-70 Website: http://metallprofil.ru
Contrast LLC Address: Krasnodar, Krasnodar, Dimitrova Str., bld. 11/3	Phone: +7 (861) 212-30-25 Website: http://krdregion.ru
MIA Construction LLC Address: Krasnodar, Krasnodar, Kommunarov Str., 268, A, office 80	Phone: +7 (918) 368-82-18
Opt dlya Optovikov LLC Address: Krasnodar, Krasnodar, Dalnaya Str., bld 43, office 404	Phone: +7 (861) 225-28-08 Website: http://barta.su
PORT LLC Address: Krasnodar, Krasnodar, Aeroportovskiy ave. bld.8	Phone: +7 (928) 257-28-98 Website: http://opt-port.ru
SpetsTorg-Krasnodar LLC Address: Krasnodar, Krasnodar, Uralskaya Btr., 144, 3rd floor, office 313, 303	Phone: +7 (861) 203-00-23 Website: http://idalgo.su
TPC Edelweiss LLC Address: Krasnodar, Krasnodar, Severskiy district, urban-type settlement Afipskiy, Smolenskoye shosse, bld. 8	Phone: +7 (861) 279-01-00 Website: http://eweiss.ru
PKF Everest LLC Address: Krasnodar, Krasnodar, Stasova Str., bld.178-180/1	Phone: +7 (861) 299 62 71 Website: http://everest-grupp.ru
METAL PROFILE Company LLC Address: Krasnodar, Krasnodar, Dinskaya village, Kraynaya Str., 14	Phone: +7 (861) 625-51-51 Website: http://metallprofil.ru
ALEA LLC Address: Krasnodar, Sochi, Mira Str., bld 25	Phone: +7 (862) 240-48-13 Website: http://aleacompany.ru
StavropolStroyIndustriya LLC Address: Krasnodar, Sochi, Olympiyskiy ave., 1	Phone: +7 (862) 260 82-39 Website: http://td-stroybaza.ru
Krovelny pirog LLC Address: Krasnodar, Novorossiysk, Lenina Str, 6B, Tsemdolina village	Phone: 8 800 707 86-17 Website: http://roofpirog.ru

Saturn-Krasnodar JSC Address: Krasnodar, Krasnodar, Uralskaya St., bld. 128	Phone: +7 (861) 212-66-00 Website: http://krd.saturn.net
Teplostroy LLC Address: Krasnodar, Krasnoyarsk, Kalinina Str., 73A	Phone: +7 (391) 268-30-82 Website: https://vsemktostroit.ru/catalog/uteplitel-na-osnove-kvartsa/
PORT LLC Address: Krasnodar, Yeisk, Michurina Str., 12/12	Phone: +7 (928) 846-58-48 Website: http://opt-port.ru
IE Verkhoturov A.Yu. Address: Krasnodar, Anapa, Anapskoe Shosse, bld. 1	Phone: +7 (861) 334-55-55 Website: http://td-piramida.ru

For purchasing materials, please contact

Alexey Voloshchuk
Sales Manager

LLC Saint-Gobain Construction Products Rus
Mobile: 89181887676
E-mail: Alexey.Voloshuk@saint-gobain.com
www.saint-gobain.ru